

# ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC  
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK  
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE  
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

## CERTIFICATE

No.: 1140824

**Product:** Technological distributor

**Type:** RT (variants see annex)

**Rating:** 3x 230/400 V, 50 Hz, IP54, to 1600 A

**Ordering firm:** KOMEL CZ s.r.o.  
Dělnická 384, 530 03 Pardubice, Czech Republic

**Manufacturer:** KOMEL CZ s.r.o.  
Dělnická 384, 530 03 Pardubice, Czech Republic

**Trade mark:**

The test results are stated in the test-report No.: 401972-01/01 of: 15.08.2014

A sample of the product was found to be in conformity with:  
ČSN EN 61439-1:12 ed.2, ČSN EN 61439-2:12, ČSN EN 60204-1 ed.2:07 cl. 10.2.1;

The validity of the certificate is limited to: 30.9.2017

25.9.2014

Prague

Miroslav Sedláček  
Head of Certification Body



Stamp



401972-01